



**MODENA CENTRO PROVE s.r.l.**





Sede legale e Laboratori: 41123 Modena (Italy) - Via Sallustio, 78  
Tel. 059822417 r.a. - Fax 059380281 - e-mail : [info@modenacentroprove.it](mailto:info@modenacentroprove.it) - [www.modenacentroprove.com](http://www.modenacentroprove.com)  
C.C.I.A.A. Modena n. 228587 - Tribunale di Modena n° 2231 - C.F. e P. IVA n. 01592020364

## TEST REPORT: 20173100/1

Modena, 16/05/17

<b>CUSTOMER</b>	<b>T.D.A. SRL - - VIA CIRCONVALLAZIONE 1 - 25020 - SAN GERVASIO BRESCIANO - BS</b>
<b>MATERIAL and/o SAMPLE to be tested</b>	shower tray;
<b>Denomination</b>	SUPERFICI IN AROCK;
<b>Date of sample reception</b>	08/05/2017;
<b>Kind of test executed</b>	Determination of Slipperiness
<b>Referring standards</b>	DIN 51097:1992
<b>Shifting from standards</b>	None
<b>Equipment</b>	Pullmeter with ramp cod. MCP C23
<b>Calibration</b>	RT n. 08 of 28/04/2014
<b>Subcontracted phases</b>	None
<b>Sampling made by</b>	Customer

*The test results showing in this Report are only referred to the sample taken by our staff or supplied by the Customer. He commits himself to reproduce integrally this document. Partial reproduction is forbidden.  
The times of retain of the samples was indicated in the offer related to the test report.*

<p><b>Examiner</b>  p.i. Nasseti Luca <b>Examiner</b>  p.i. Bortolai Alberto</p>	<p><b>MODENA CENTRO PROVE</b>  Ceramic Dept. Responsible P.I. De Pasquale Roberto</p>	<p><b>MODENA CENTRO PROVE</b>  Director Sant'Unione dr. Giuseppe</p>
--	--	---



## DETERMINATION OF SLIPPERINESS

Beginning date : 10/5/17

Analysis ending date : 11/5/17

**SAMPLE** : Ceramic tiles, marked « **SUPERFICI IN AROCK** »

A person walks backwards and forwards barefoot across the tiles to be tested, the inclination of which is increased by about 1° per second; the angle of inclination at which the person is no longer in conditions of safety is defined as the slip angle. The surface is wet continuously with a solution ( 1 g/l of wetting agent + water ).

### RESULTS

- Sample dimensions (length, width) : 1x 0.5 (m)
- Width of joints : //
- Groutig substance : //
- D of profiles : none
  
- SLIP ANGLE : 19.2°
- CLASSIFICATION : B(A+B)

### CLASSIFICATION

Total Average Values	Group Classification
< 12	0
≥ 12°	A
≥ 18°	B
≥ 24°	C

Examiner  
  
p.i. Nasseti Luca  
Examiner  
  
p.i. Bortolai Alberto

MODENA CENTRO PROVE  
  
Ceramic Dept. Responsible  
P.I. De Pasquale Roberto

MODENA CENTRO PROVE  
  
Director  
Sant'Unione dr. Giuseppe